


Sec. A-A



Pipes should not be fixed but should be positioned near connection after the backfilling.
connections must be performed after installation of the unit

N.B. Connections, backfill, and finishing must be done after APT laying

Rev. 1 Data 19/01/2014 Nota

CODIFICA DISIGNO

95133 RD-Fondazione PREF-TMAX 2014

OGGETTO

T WAW FOUNDATION



PTMA S.p.A.
20010 Bolognola (MI)
www.ptma.it

Materiale: concrete RCK 20/30 with double electrostatically welded net Ø9x20x20
Note: PLANIMETRIA E SEZIONE

7 scale

Scale

1:15

Dis. da

L. Maresioni

Appr. da